<u></u>			
	Application No.	Applicant(s)	
	10/713,346	JOHNSON ET AL.	
Notice of Allowability	Examiner	Art Unit	
	Derek S. Boles	3749	
The MAILING DATE of this communication apper All claims being allowable, PROSECUTION ON THE MERITS IS herewith (or previously mailed), a Notice of Allowance (PTOL-85) NOTICE OF ALLOWABILITY IS NOT A GRANT OF PATENT RI of the Office or upon petition by the applicant. See 37 CFR 1.313	(OR REMAINS) CLOSED in this apport or other appropriate communication GHTS. This application is subject to	plication. If not include will be mailed in due	ed course. THIS
1. This communication is responsive to <u>3/29/04</u> .			
2. ☑ The allowed claim(s) is/are <u>1-19</u> .	•		
3. \boxtimes The drawings filed on <u>29 March 2004</u> are accepted by the l	Examiner.		
4.			
 Attachment(s) 1. ☑ Notice of References Cited (PTO-892) 2. ☐ Notice of Draftperson's Patent Drawing Review (PTO-948) 3. ☑ Information Disclosure Statements (PTO-1449 or PTO/SB/0 Paper No./Mail Date 11/13/03 4. ☐ Examiner's Comment Regarding Requirement for Deposit of Biological Material 	5. ☐ Notice of Informal P 6. ☐ Interview Summary Paper No./Mail Da 8), 7. ☐ Examiner's Amendr 8. ☒ Examiner's Stateme 9. ☐ Other	(PTO-413), te ment/Comment	ŕ

Art Unit: 3749

REASONS FOR ALLOWANCE

The following is an examiner's statement of reasons for allowance: The prior art of record, neither singly nor in combination, disclose a heat rejecting radiator for selective connection to receive liquid coolant from the engine, reject heat from the coolant and return the coolant to the engine when outside temperature is above a predetermined value, a second heat exchanger positioned within the building and having a third flow path for selective connection, alternatively to the radiator, for circulation of liquid coolant from the engine, and a fourth flow path, for selective connection to receive the heating water from the heater prior to circulation of the heating water through the second flow path and first means selectively operable to control flow of the coolant between the radiator and the third flow path and second means selectively operable to control flow of the heating water between a direct connection from the heater to the second flow path and connection to the fourth flow path and thence to the second flow path.

Any comments considered necessary by applicant must be submitted no later than the payment of the issue fee and, to avoid processing delays, should preferably accompany the issue fee. Such submissions should be clearly labeled "Comments on Statement of Reasons for Allowance."

Conclusion

The prior art made of record and not relied upon is considered pertinent to applicant's disclosure. The provided references are representative of the state of the art that is applicable to the applicant's invention. Any inquiry concerning this communication or earlier communications from the examiner should be directed to Derek S. Boles at (571) 272-4872.

D.S.B.

DERES S. BOLES
PRIMARY EXAMINER
GROUP 3700

6/13/05